



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services

Paschim Bardhaman Division, 1st Floor, Durgapur Fire Station Building, City Centre, Durgapur-16

Memo No.: FSR/IND/WB/FES/20192020/ 60035

Date : 18-03-2026

From :
Divisional Fire Officer
Paschim Bardhaman Division,
West Bengal Fire & Emergency Services

To :
DURGAPUR PUBLIC INSTITUTE SECRETARY, B. CHATTERJEE
EMAN KALYAN SARANI 2C BIDHAN NAGAR DURGAPUR OVER PLOT NO.215(P),217(P),219(P),KH NO.147,151,163
MOUZA.GOPINATHPUR JL NO.85 PS.DURGAPUR DIST.PASCHIM BURDWAN.713212

Sub : Renewal of Fire Safety Certificate for existing G+I storied Educational occupancy in the name and style as 'DURGAPUR PUBLIC INSTITUTE in favour of SECRETARY - B. CHATTERJEE' at EMAN KALYAN SARANI 2C BIDHAN NAGAR DURGAPUR OVER PLOT NO.215(P),217(P),219(P),KH NO.147,151,163 MOUZA.GOPINATHPUR JL NO.85 PS.DURGAPUR DIST.PASCHIM BURDWAN.713212.

This is in reference to your AIN 211912606300010304 dated 17-Mar-2026 regarding Renewal of Fire Safety Certificate for existing G+I storied Educational occupancy in the name and style as 'DURGAPUR PUBLIC INSTITUTE in favour of SECRETARY - B. CHATTERJEE' at EMAN KALYAN SARANI 2C BIDHAN NAGAR DURGAPUR OVER PLOT NO.215(P),217(P),219(P),KH NO.147,151,163 MOUZA.GOPINATHPUR JL NO.85 PS.DURGAPUR DIST.PASCHIM BURDWAN.713212..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010304

1. Maintenance/checking testing of all fire safety installations shall be checked time to time.
2. No change of occupancy shall be allowed in respect of the approved plan drawing.
3. Any nominated officer of this Department shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire Prevention and Fire Safety Measures.
4. Mock Drill must be performed twice in a year and recorded properly.
5. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
6. No parking will be allowed on the Driveway.
7. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
8. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the buildings shall be strictly maintained.
9. Existing Electrical wiring of the buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
10. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable areas of the site.
11. The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire and Testing.
12. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
13. First-Aid Fire Fighting system shall be provided as per I.S. specification.
14. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
15. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
16. The Fire Safety Audit is to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.
17. Violation of any recommendations which issued from this office previously this renewal of fire safety certificate shall be treated as cancelled and no further renewal would be made.
18. This Renewal of Fire Safety Certificate is valid for three years as per existing Govt. Notification and has to be renewed in due time.

Valid Upto : 16-Mar-2029

**Memo No.: FSR/IND/WB/FES/20192020/
60035**



Signature valid

Digitally Signed.
Name: Amallesh Barua
Date: 18-Mar-2020 15:53:14
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010304